


# CERTIFICATE

Certified Passive House Component

Component-ID 0022wc03 valid until 31st Decembar 2019

Passive House Institute  
Dr. Wolfgang Feist  
64283 Darmstadt  
Germany



Category: **Window connection**


Manufacturer: **OPTIWIN GmbH,  
Ebbs,  
Austria**

Product name: **Alu2Holz**

**This certificate was awarded based on the following  
criteria for the cool, temperate climate zone**

Comfort  $U_{W,installed} \leq 0.85 \text{ W}/(\text{m}^2 \text{ K})$   
with  $U_g = 0.70 \text{ W}/(\text{m}^2 \text{ K})$

Hygiene  $f_{Rsi=0.25} \geq 0.70$



Passive House  
efficiency class

phE

phD

phC

phB


phA

cool, temperate climate




**CERTIFIED  
COMPONENT**

Passive House Institute



Calculation model



Isothermal

## Description

Timber frame with insulation. Certificate only valid for installation in timber construction wall

## Explanation

The window U-values were calculated for the test window size of 1.23 m × 1.48 m with  $U_g = 0.70 \text{ W}/(\text{m}^2 \text{ K})$ . If a higher quality glazing is used, the window U-values will improve as follows:

Glazing	$U_g =$	0.70	0.64	0.58	0.53	W/(m <sup>2</sup> K)
		↓	↓	↓	↓	
Window	$U_W =$	0.82	0.78	0.74	0.70	W/(m <sup>2</sup> K)




Transparent building components are classified into efficiency classes depending on the heat losses through the opaque part. The frame U-Values, frame widths, thermal bridges at the glazing edge, and the glazing edge lengths are included in these heat losses. A more detailed report of the calculations performed in the context of certification is available from the manufacturer.

The Passive House Institute has defined international component criteria for seven climate zones. In principle, components which have been certified for climate zones with higher requirements may also be used in climates with less stringent requirements. In a particular climate zone it may make sense to use a component of a higher thermal quality which has been certified for a climate zone with more stringent requirements.

Further information relating to certification can be found on [www.passivehouse.com](http://www.passivehouse.com) and [passipedia.org](http://passipedia.org).

Frame values			Frame width $b_f$ mm	U-value frame $U_f$ W/(m <sup>2</sup> K)	$\Psi$ -panel edge $\Psi_g$ W/(m K)	Temp. Factor $f_{Rsi=0.25}$ [-]
Top	(to)		118	0.83	0.026	0.73
Side	(s)		118	0.83	0.026	0.73
Bottom	(bo)		118	0.99	0.025	0.73
Mullion flying	(fm)		130	0.99	0.029	0.70
			Spacer: Super Spacer TriSeal / T-Spacer Premium		Secondary seal: Polyurethane	

### Validated installations

EIFS		Insulated formwork blocks		Timber frame	
					
$\Psi_{install}$	W/(m K)	$\Psi_{install}$	W/(m K)	$\Psi_{install}$	W/(m K)
Top	-0.002	Top	-0.001	Top	0.006
Side	-0.002	Side	-0.001	Side	0.006
Bottom	0.013	Bottom	0.015	Bottom	0.024
$U_{W,installed} = 0.82$ W/(m <sup>2</sup> K)		$U_{W,installed} = 0.83$ W/(m <sup>2</sup> K)		$U_{W,installed} = 0.85$ W/(m <sup>2</sup> K)	

